

Donna E. Palley
Assistant Superintendent

Robert Belmont
Director, Student Services

Jack Dunn
Business Administrator

Larry Prince
Director, Human Resources

Matt Cashman
Director, Facilities & Planning

December 6, 2018

Dear Parents and Guardians,

New Hampshire's new Lead Bill SB 247, "Preventing Childhood Lead Poisoning from Paint and Water", was adopted in Feb. 2018 and requires lead testing in drinking water by July 1, 2019, at all locations where water is available for consumption by children at all schools and licensed childcare facilities in the state.

We recently completed testing of all elementary school locations where children can drink water within the Concord School District. For reference, the lead action level in drinking water is 15 parts per billion (ppb) or 0.015 mg/L, though the goal is for NO lead exposure to children from any source.

Rundlett Middle School and Concord High School will also be tested during the winter months in 2019.


In accordance with the testing protocol, the stagnant lead test results for Concord School District were obtained as follows:

Test Location	Sample Date	Lab Report Date	Stagnant Lead, ppb (mg/L)
1. Abbot-Downing*	Nov 13, 2018	Nov 14, 2018	<1 ppb (<0.001 mg/L)
2. Beaver Meadow*	Nov 1, 2018	Nov 2, 2018	<1 ppb (<0.001 mg/L)
3. Broken Ground*	Oct 29, 2018	Oct 29, 2018	<1 ppb (<0.001 mg/L)
4. Christa McAuliffe*	Nov 6 & 8, 2018	Nov 9, 2018	<1 ppb (<0.001 mg/L)
5. Mill Brook*	Nov 2, 2018	Nov 2, 2018	<1 ppb (<0.001 mg/L)
6. Eastman*	Oct 26, 2018	Oct 26, 2018	<1 ppb (<0.001 mg/L)

*Individual school results are available at the Office of Superintendent, 38 Liberty Street, Concord, NH.

We are available to answer any questions or to provide any additional information by making an appointment with Matt Cashman, Director of Facilities and Planning, 603-225-0847, mcashman@sau8.org. In addition, the state has additional background and resources for consultation available by a simple web search for "[NHDES Lead in Drinking Water](#)".

Sincerely,



Matt Cashman